



AUTHORIZATION TO MARK

This authorizes the application of the Certification Mark(s) shown below to the models described in the Product(s) Covered section when made in accordance with the conditions set forth in the Certification Agreement and Listing Report(s). This authorization also applies to the Multiple Listee model(s) identified on the correlation page of the Listing Report.

This document is the property of Intertek Testing Services and is not transferable. The Certification Mark(s) may be applied only at the location of the Party Authorized to Apply Mark.

Applicant: AMERICAN MOTORS – CH. PILALIS S.A.
 5, Protomagias Street, Industrial Zone, Krioneri
 Athens, Attica 14568
 Greece

Contact: Mrs. Violetta Pilali

Phone: +302106220100

Fax: +302108161916

Email: violettapilali@gmail.com

Party Authorized to Apply Mark: See following page(s)

Evaluation Center: Intertek (Middle East)

Client Number: 391477

Authorized By: 
Jean-Philippe Kayl, Director of Certification

Intertek Testing Services NA, Inc.
 545 E. Algonquin Road, Ste H., Arlington Heights, IL 60005 USA
 Phone: 847-439-5667 Fax: 847-439-7320



This document supersedes all previous Authorizations to Mark for the noted Report Number.

This Authorization to Mark is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Authorization to Mark. Only the Client is authorized to permit copying or distribution of this Authorization to Mark and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement and in this Authorization to Mark. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.

Testing Standard(s):	EN 1634-1:2014+A1(2018), UL 10(b) (2008) (R2020)
Product:	AMP - FireFreeze S90 Sliding Single Door and Frame Assembly - UL 10B / EN 1634-1

ATM for Spec Id: 85207

ATM Issue Date: 3/23/2026

Listing Section(s): CATEGORY D - DOOR/FRAME ASSEMBLIES

CSI Code(s): 08 10 00 Doors and Frames

Description:

Product Covered

AMP - FireFreeze S90 Sliding Single Door and Frame Assembly - UL 10B / EN 1634-1

Product Description

Latched Single Horizontal Sliding Cold Room Fire Door "FireFreeze S90"

Door leaf is constructed with 1.00mm thick mild steel sheet with ceramic fibre boards and polyurethane boards as infill material. Sliding system is constructed with a 2.00mm thick stainless steel. For assembly on masonry supporting walls.

Tested Leaf Size: 1920mm x 2600mm x 120mm (w x h x t)

Fire Ratings

The product noted above has been evaluated according to the requirements of the standard UL 10B and has qualified for up to **90 minutes** (1-1/2 hour) fire rating.

The product noted above has been evaluated according to the requirements of the standard EN 1634-1 and has qualified for up to **E 90/EI₂ 60 / EI₁ 45** fire rating.

Alternative UL 10B listed/labeled hardware allowed for use with metal based fire doors may be installed.

Note: Door, Frame and Hardware must be shipped together from the factory as an assembly.

Party(s) Authorized by Manufacturer To Apply Mark:

AMERICAN MOTORS – CH. PILALIS S.A.
5, Protomagias Street, Industrial Zone, Krioneri
Athens, Attica 14568
Greece
Contact: Mrs. Violetta Pilali
Phone: +302106220100
Fax: +302108161916
Email: violettapilali@gmail.com

Party(s) Authorized by Other Parties To Apply Mark:

None