



EFFECTIS ERA AVRASYA TEST ve BELGELENDİRME AŞ
Dilovası OSB Mahallesi Fırat Caddesi No: 18
Dilovası, Kocaeli / TÜRKİYE
www.efectis.com

DECLARATION OF TEST RESULTS

No: EEA – 1900 – 0037 - REV

The fire resistance test was carried out for the product as described below at Efectis Era Avrasya Test Laboratory on 05.02.2019 in accordance with the test standard:

EN 1634-1:2014+A1:2018

“SKSDFP90”
FIRE RATED COLD ROOM DOOR

FIRE RESISTANCE CLASSIFICATION	
Direction: Sliding supporting components fixed on the face of the supporting wall on fire side	E90, EI₂90, EI₁60
Direction: Sliding supporting components fixed on the face of the supporting wall on unexposed side	E90

Placed on the market by: **AMERICAN MOTORS PILALIS S.A**
Protomagias 5, str., Ind. Zone Krioneri 14568 Athens/GREECE

Manufactured by: **AMERICAN MOTORS PILALIS S.A**
Protomagias 5, str., Ind. Zone Krioneri 14568 Athens/GREECE

Ali BAYRAKTAR
Laboratory Manager
02.03.2021

This document is a declaration of test results and does not represent any type of approval or certification of the product. All details related to product specifications and field of applications are described in the report No: EEA-19-046.

