

Certificate of Compliance



You have been awarded:

Intertek WH US Mark for Category C - Proprietary Frames

Standards: UL 10(c) (2016), UL 10(b) (2008) (R2015), NFPA 252 (2022)

Certificate number: WHI23-39147702

This is a certificate of compliance to certify that the bearer has successfully completed the requirements of the above scheme which include the testing of products, the initial assessment, and are subject to continuing annual assessments of their compliance and testing of samples of products taken from production (as applicable to the scheme) and has been registered within the scheme for the products detailed.

Organization: AMERICAN MOTORS – CH. PILALIS S.A.
5, Protomagias Street, Industrial Zone, Krioneri
Athens, Attica 14568
Greece

Product: AMP - Cold Room Fire Door Frame “FireFreeze” - 90 Minutes - UL 10C
Spec ID: 74697
Fire Rating: 60 Min PP Category C Proprietary Frame, 90 Min PP Category C Proprietary Frame
Listing Information: See following page(s)

Certification body: Intertek Testing Services NA, Inc.
Initial registration: November 21, 2023
Date of expiry: December 31, 2024
Issue status: 2

Authorized By: 
Jean-Philippe Kayl, Director of Certification

Intertek Testing Services NA, Inc.
545 E. Algonquin Road, Ste H., Arlington Heights, IL 60005 USA
Phone: 847-439-5667 Fax: 847-439-7320

www.intertek.com

The certificate and schedule are held in force by regular annual surveillance visits by Intertek Testing Services NA, Inc. and the reader or user should contact Intertek to validate its status. This certificate remains the property of Intertek Testing Services NA, Inc. and must be returned to them on demand. This Certificate is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this certificate. Only the Client is authorized to permit copying or distribution of this certificate and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.

LISTING INFORMATION

Product Covered

AMP - Cold Room Fire Door Frame "FireFreeze" - 90 Minutes - UL 10C
Category C - Proprietary Frames.

Product Description

Latched Single Acting Single Leaf Hinged Cold Room Fire Door "FireFreeze"

Four-sided frame is constructed with a 1.50mm thick stainless steel sheet with a jamb depth of 247mm.

Tested Sizes:

Single leaf door frame: 1384 x 2392mm (w x h x thk.)

Limitations:

Door frame must be infilled with mineral wool or cement grouting.

Fire Ratings

The product noted above has been evaluated according to the requirements of the standard UL 10C and has qualified for up to **90 minutes (1-1/2 hours)** positive pressure fire rating.

Also meets the requirements of UL 10B (Negative Pressure Fire Rating) and NFPA 252 (Positive Pressure Fire Rating).