



LISTING INFORMATION OF

AMP - Cold Room Fire Door “FireFreeze” - 90 Minutes - UL 10C

SPEC ID: 74696

AMERICAN MOTORS – CH. PILALIS S.A.
5, Protomagias Street, Industrial Zone, Krioneri
Athens, Attica 14568
Greece

This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to permit copying or distribution of this report and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample tested. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

LISTING INFORMATION

Product Covered

AMP - Cold Room Fire Door "FireFreeze" - 90 Minutes - UL 10C
CATEGORY B DOORS - ADDITIONAL EDGE-SEALING SYSTEM REQUIRED.

Product Description

Latched Single Acting Single Leaf Hinged Cold Room Fire Door "FireFreeze"

Door leaf is constructed with 1.00mm thick mild steel sheet with ceramic fibreboards and polyurethane boards as infill material.

Tested Sizes:

Single leaf door: 1170 x 2275 x 120mm (w x h x thk.)

Limitations:

Minimum Latch Throw - 19mm (Listed surface mounted rim type panic device).

Door surface can be coated with rigid PVC with maximum thickness of 200 microns.

Fire Ratings

The product noted above has been evaluated according to the requirements of the standard UL 10C and has qualified for up to **90 minutes (1-1/2 hours)** positive pressure fire rating.

Also meets the requirements of UL 10B (Negative Pressure Fire Rating) and NFPA 252 (Positive Pressure Fire Rating).

Note: Doors must be installed in listed AMP Category C steel frames or listed Category C standard frames.

Attribute	Value
Certificate Date of Expiry	December 31, 2024
Certificate Date of Initial Registration	November 01, 2023
Certificate Number	WHI23-39147701
Criteria	UL 10(c) (2016)
Criteria	UL 10(b) (2008) (R2015)
Criteria	NFPA 252 (2017)
Criteria	UL 10(b) (2008) (R2020)
CSI Code	08 10 00 Doors and Frames
Fire Resistance	90 Min PP Category B Door
Fire Resistance	60 Min PP Category B Door
Intertek Services	Certification
Listed or Inspected	LISTED
Listing Section	CATEGORY B - DOORS - ADDITIONAL EDGE-SEALING SYSTEM REQUIRED
Spec ID	74696