



LISTING INFORMATION OF  
**AMP - Cold Room Fire Door Frame “FireFreeze” - 90  
Minutes - UL 10C**  
SPEC ID: 74697

AMERICAN MOTORS – CH. PILALIS S.A.  
5, Protomagias Street, Industrial Zone, Krioneri  
Athens, Attica 14568  
Greece

This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to permit copying or distribution of this report and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample tested. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

## LISTING INFORMATION

### Product Covered

AMP - Cold Room Fire Door Frame "FireFreeze" - 90 Minutes - UL 10C  
Category C - Proprietary Frames.

### Product Description

Latched Single Acting Single Leaf Hinged Cold Room Fire Door "FireFreeze"

Four-sided frame is constructed with a 1.50mm thick stainless steel sheet with a jamb depth of 247mm.

### Tested Sizes:

Single leaf door frame: 1384 x 2392mm (w x h x thk.)

### Limitations:

Door frame must be infilled with mineral wool or cement grouting.

### Fire Ratings

The product noted above has been evaluated according to the requirements of the standard UL 10C and has qualified for up to **90 minutes (1-1/2 hours)** positive pressure fire rating.

Also meets the requirements of UL 10B (Negative Pressure Fire Rating) and NFPA 252 (Positive Pressure Fire Rating).

Attribute	Value
Certificate Date of Expiry	December 31, 2024
Certificate Date of Initial Registration	November 21, 2023
Certificate Number	WHI23-39147702
Criteria	UL 10(c) (2016)
Criteria	UL 10(b) (2008) (R2015)
Criteria	NFPA 252 (2022)
CSI Code	08 10 00 Doors and Frames
Fire Resistance	60 Min PP Category C Proprietary Frame
Fire Resistance	90 Min PP Category C Proprietary Frame
Intertek Services	Certification
Listed or Inspected	LISTED
Listing Section	CATEGORY C - PROPRIETARY FRAMES
Spec ID	74697